



08 DEC 26 P1:9

STATE PROCUREMENT OFFICE EMERGENCY PROCUREMENT REQUEST

1. TO: Chief Procurement Officer
2. FROM: Public Safety / Corrections / Kulani Correctional Facility

Department/Division/Agency

Pursuant to §103D-307, HRS, and Subchapter 10, Chapter 3-122, HAR, the Department requests approval for the following:

3. Date	4. After the fact <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
5. Nature of the Emergency Health and safety issues due to the sulfur dioxide emissions from the volcanic eruptions of Halemaumau and Puuoo at the Volcano National Park exceeding HIOSH permissible exposure levels of 2.0 ppm over an 8 hour period. HIOSH performed a consultation on December 2 through 3, 2008 (report attached- Attachment A) with the recommendation for immediate action. See attached additional information.	

6. Vendor: TO BE DETERMINED Address:	7. Price: \$60,000.00
---	--------------------------

8. Description of goods, services, or construction to be purchased
Approximately 25 portable air purifiers with media containing alumina, and potassium permanganate for sulfur dioxide removal, a prefilter and HEPA filter for particulate removal. (Attachment B - received December 19, 2008, accepting IQ Air GCX Chemsorber as an acceptable engineering control to reduce employee exposure to sulfur dioxide.)

9. Reason for Vendor Selection
Propose reissuing an informal bid to the three vendors distributing the IQ Air model GCX Chemsorber air purifier.

10. Direct questions to: Marc S. Yamamoto, PSS IV *msy 12/24/08* Phone: 808-587-1215

11. I certify that the information provided above is to the best of my knowledge, true and correct.

Clayton A. Frank 12/24/08
Department Head Clayton A. Frank, Director Date

Reserved for SPO Use Only

12. Chief Procurement Officer's comments:
Procurement shall be conducted using small purchase method of procurement utilizing HePS. The request shall be made available for a minimum period of at least five business days. Agency may specify the brand of choice but allow for "or equal product".

13. APPROVED DISAPPROVED NO ACTION REQUIRED
Adam S. Fyler 1/5/09
Chief Procurement Officer Date

Additional Information:

As stated on Attachment A, page 3, 1st full paragraph, Kulani Correctional Facility (KCF) utilizes a shelter in place. After the initial attacks early this year, KCF replaced louvered and jalousie windows to provide shelter in place. As reported in the findings of Attachment A, these measures did reduce the exposure to staff and inmates, but the interior levels still remained above the 2.0 PPM PEL (9.9 ppm outside vs 6.9 ppm inside).

An emergency exists because of the unpredictability of the volcanic emissions and that previous measures taken were not adequate for a shelter in place.

As required by Attachment A to provide protective measures for employees (and inmates) and as accepted by HIOSH, PSD would like to purchase the IQ Air GCX Chemsorber as part of the protective measures required.