



'10 DEC 23 P1:24

STATE PROCUREMENT OFFICE
EMERGENCY PROCUREMENT REQUEST

STATE PROCUREMENT OFFICE
STATE OF HAWAII

- 1. TO: Chief Procurement Officer
- 2. FROM: Kaulana H.R. Park, Chairman Hawaiian Homes Commission

Department/Division/Agency

Pursuant to §103D-307, HRS, and Subchapter 10, Chapter 3-122, HAR, the Department requests approval for the following:

3. Date 12/22/2010

4. After the fact YES NO

5. Nature of the Emergency

While investigating a fault at the 300 hp Well #2 on Moloka'i, it was discovered that an 8" Cla-Val pump control valve on the discharge of the pump is broken internally. This valve pumps water from Well #2 into the tank that supplies water to the Ho'olehua and Kalama'ula area. Threat to health and safety: While the valve is broken, the tank cannot be filled. This will stop water to the residents of this region.

6. Vendor: Pacific Electro-Mechanical, Inc.
Address: 192 Mohonua Place #E
Honolulu, HI 96819

7. Price:
\$7,491.15

8. Description of goods, services, or construction to be purchased
8" Cla-Val pump control valve plus labor to install.

9. Reason for Vendor Selection

Pacific Electro-Mechanical, Inc. is currently on-site and discovered the fault when attempting to fill the well.

10. Direct questions to: Kamana'o Mills

Phone: 620-9508

11. *I certify that the information provided above is to the best of my knowledge, true and correct.*

Kaula Park
Department Head

12/23/10
Date

Reserved for SPO Use Only

12. Chief Procurement Officer's comments:

This award is required to be posted on the Awards Reporting System.

13.

APPROVED DISAPPROVED NO ACTION REQUIRED

Carol J. J... 2/9/2011
Chief Procurement Officer Date

14. E.P.No. 11-008D