



MAR -1 P2:15

STATE PROCUREMENT OFFICE
EMERGENCY PROCUREMENT REQUEST

STATE PROCUREMENT OFFICE
STATE OF HAWAII

1. TO: Chief Procurement Officer

2.FROM: DLNR, State Parks

Department/Division/Agency

Pursuant to §103D-307, HRS, and Subchapter 10, Chapter 3-122, HAR, the Department requests approval for the following:

3. Date 2/16/11 4/23/2010
4. After the fact [X] YES [] NO
5. Nature of the Emergency
Make electrical circuits safe and replace burnt electrical wires that supply power to the sewer pump station #1 at Sand Island State Park. Public health and safety was a concern due the sewer pumps not pumping in turn backing up the toilets and raising raw sewage to an overflow level in the holding tanks.

6. Vendor: Wasa Electrical Service, Inc.
Address: 2908 Kaihikapu St.
Honolulu, HI 96819
7. Price: \$33,283.21

8. Description of goods, services, or construction to be purchased
Return circuits to safe operation and replacing burnt electrical wires in the underground conduit running from the transformer box to the sewer pump station.

9. Reason for Vendor Selection
Wasa Electrical Service, Inc. was the only electrical contractor with a high voltage electrician able to respond immediately before any sewage overflowed onto the property and made the determination that an electrical short within the electrical system turned of power to the sewer pumps.

10. Direct questions to: Eric Kato Phone: 733-9102

11. I certify that the information provided above is to the best of my knowledge, true and correct.

Department Head [Signature] Date 3/1/11

Reserved for SPO Use Only

12. Chief Procurement Officer's comments:
Approval is based on department's determination that the electrical shortages were unanticipated and repairs to electrical circuits and electrical wires were necessary due to health concerns for park users. This award is required to be posted on the Awards Reporting System.

13. [X] APPROVED [] DISAPPROVED [] NO ACTION REQUIRED
Chief Procurement Officer [Signature] Date 3/7/2011

14. E.P.No. 11-018-0