

P50# 2011-1046



11 JUN 15 A9:27

STATE PROCUREMENT OFFICE
EMERGENCY PROCUREMENT REQUEST

RUSH

1. TO: Chief Procurement Officer
2. FROM: Department of Public Safety

Department/Division/Agency

Pursuant to §103D-307, HRS. and Subchapter 10, Chapter 3-122, HAR. the Department requests approval for the following:

3. Date 6/14/2011

4. After the fact YES NO

5. Nature of the Emergency
On June 4, 2011, 10:00 pm, the pad mounted transformer caught fire and was damaged beyond repair.

The transformer is connected to the WCF emergency generator which powers the entire 334 bed facility in the event of HECO power outage. The emergency generator cannot be used without this transformer leaving WCF without any power.

6. Vendor: Ted's Wiring Service, Ltd.
Address: 500 Ala Kawa Street, Ste 222
Honolulu, Hawaii 96817

7. Price:
\$21,070.00

8. Description of goods, services, or construction to be purchased
Remove and dispose of existing transformer, replace with new.

9. Reason for Vendor Selection
The facility contacted Paul's Electric and was advised that they did not have any of this type of transformer in stock and would require a lead time of a couple weeks. Ted's Wiring has this type of transformer in stock.

10. Direct questions to: Walter Zaharcvitz Phone: 677-7150
Walter Zaharcvitz 677-7150

11. I certify that the information provided above is to the best of my knowledge, true and correct.

[Signature] Department Head 6/14/11 Date

12. Chief Procurement Officer's comments:
Approval is granted based on the department's determination that replacing the inoperable emergency transformer generator is necessary due to potential security, safety, and health risks to staff and inmates at the Waiawa Correctional Facility if the main generator fails. This award is required to be posted on the Awards Reporting System.

13. APPROVED DISAPPROVED NO ACTION REQUIRED

[Signature] Chief Procurement Officer Date 6/20/2011
14. E.P.No. 11-046-B