



**STATE PROCUREMENT OFFICE
EMERGENCY PROCUREMENT**

15 MAR -5 P1:42

TO: Chief Procurement Officer

FROM: Department of Transportation, Harbors Division
Name of Requesting Department

ADMINISTRATION
STATE PROCUREMENT OFFICE
STATE OF HAWAII

Pursuant to HRS § 103D-307 and HAR chapter 3-122, Subchapter 10, the Department requests approval for the following:

1. Date or period of Emergency: 2/21/2015	2. After-the-Fact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
---	--

3. Describe in detail the emergency situation that created a threat to life, public health, welfare or safety.
Heavy flooding from an unforeseen break in the fire service line for the Pier 3 container yard at Nawiliwili Harbor was discovered and the valve for the fire line had to be closed. See attached incident report. Closing the valve renders 12 acres, or the entire Interisland Container facility, without fire protection service. Should there be a fire, an increased life safety, health, and property threat would be present, as the ability to fight the fire would not meet the fire code. It is anticipated that the break in the fire line may have created large voids under the concrete slab. Repairs to the voids under the slab may be required to prevent failure/collapse of the pavement and possible injury to equipment operators.

4. Vendor/Contractor/Service Provider Name: Pacific Concrete Cutting and Coring, Inc.	5. Amount of Request: \$ 100,000
--	-------------------------------------

6. Describe in detail the emergency goods, services, or construction and explain why it is necessary.
Locate and repair the 12-inch fire service line within the Pier 3 container yard to meet life safety requirements. Work includes, but is not limited to: sawcutting the existing concrete slab; excavation to expose damaged fire line; repair fire line; backfill with CLSM or aggregate base; embed rebar into existing slab; installing new concrete slab; concrete coring to determine voids under the pavement, and filling voids with suitable material.

7. State the reason(s) the vendor/contractor/service provider was selected. Explain what competition, as is practicable, was conducted.
Vendor is only company on Kauai able to sawcut through 16" of concrete pavement. Vendor is immediately able to begin repair work. They recently completed a Harbors project at Nawiliwili Harbor with outstanding service and quality, and have the necessary security credentials.

8. Identify the primary responsible staff person(s) conducting and managing this procurement. (Appropriate delegated procurement authority and completion of mandatory training required.)

*Point of contact (Place asterisk after name of person to contact for additional information.)

Name	Division/Agency	Phone Number	E-mail Address
Arnold Fukumoto <i>af</i>	Harbors/DOT	587-1878	arnold.fukumoto@hawaii.gov

All requirements/approvals and internal controls for this expenditure is the responsibility of the department. I certify that the information provided is to the best of my knowledge, true and correct.

af

 Department Head Signature 3.2.15

 Date

For Chief Procurement Officer Use Only

Chief Procurement Officer (CPO) Comments:

Approval is granted based on the department's determination that immediate action was necessary to locate and repair the 12-inch fire service line within the Pier 3 container yard at Nawiliwili Harbor, and prevent a threat to public health and safety due to the broken line. Pursuant to HRS section 103D-310(c) and HAR section 3-122-112, the procuring officer shall verify compliance (i.e. vendor is required to provide proof of compliance and may use the Hawaii Compliance Express) and award is required to be posted on the Awards Reporting System. Copies of compliance and awards posting are required to be documented in the procurement/contract file.

If there are any questions, please contact Stacey Kauleinamoku at 586-0571, or stacey.l.kauleinamoku@hawaii.gov.

15 MAR -2 A7:38

HARBORS DIVISION

15 FEB 27 P 3:48

HARBORS DIVISION

Approved Disapproved No Action Required

_____ *af*
 Chief Procurement Officer Signature Date