

'05 AUG 22 P2:50

# STATE OF HAWAII REQUEST FOR EMERGENCY PROCUREMENT

STATE PROCUREMENT OFFICE  
STATE OF HAWAII

TO: Chief Procurement Officer

FROM: DLNR/DIVISION OF BOATING & OCEAN RECREATION  
(Department/Division/Agency)

Pursuant to §103D-307, HRS and Subchapter 10, Chapter 3-122, HAR, the Department requests approval for this emergency procurement.

Date:	After the fact: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Nature of the Emergency:	
<b>SEE ATTACHED</b>	


Vendor:	Amount:
<b>IDEAL CONSTRUCTION, INC.</b>	<b>\$51,500.00</b>

Description of goods, services, or construction to be purchased:
<b>SEE ATTACHED</b>

Reason for Vendor Selection:
<b>SEE ATTACHED</b>


Direct questions to: RICHARD RICE Phone: 587-1966

I certify that the information provided above is, to the best of my knowledge, true and correct.

 8/22/05  
 \_\_\_\_\_ Date  
 Deputy - Land  
 \_\_\_\_\_  
 Title (If other than Department Head)

Chief Procurement Officer's Comments:

APPROVED       DISAPPROVED

 8/24/05  
 \_\_\_\_\_ Date  
 Chief Procurement Officer

**Nature of the Emergency:**

A 2" waterline servicing 3 "live onboard" piers, (90 boating families) at the Keehi Small Boat Harbor has been broken and is in need of replacement. While replacing a gate valve, the contractor noticed that the existing waterline was leaking and very deteriorated. Due to the age of the waterline, it was decided that repair to the leaking area was not feasible and complete replacement was the only alternative. A portable "water buffalo" was dispatched to the site on Thursday, August 18, 2005 to provide potable water to the 90 boating families. The water buffalo will be maintained until permanent water service is reestablished. An expeditious replacement of the water line to provide normal water service to the affected boaters is necessary to comply with the public health and safety requirements.

**Description of Goods, Services or Construction to be Purchased:**

Services shall include but not be limited to furnish materials, labor and equipment to install approximately 352 lineal feet of 2-inch copper underground water pipe and 1-inch copper underground water lateral connection to the 3 piers, including testing and chlorination.

**Reason for Vendor Selection:**

Three contractors were contacted and we received proposals from each to replace the waterline. The low bid contractor, Ideal Construction Inc. was the contractor on site that was replacing the gate valve. They are already mobilized, familiar with the situation and ready to begin work to replace the waterline. Reestablishing normal water service to the boating families as quickly as possible to comply with the public health and safety requirements is needed.