'07 SEP 12 P1:11

'07 SEP 19 AM 7:7

HARBORS DIVISION

STATE PROCUREMENT OFFICE
EMERGENCY PROCUREMENT REQUEST

HAR-EM
5511.08

1. TO: Chief Procurement Officer

DATE: SEPTEMBER 11, 2007

2. FROM: Transportation/Harbors/Engineering Maintenance

Department/Division/Agency

Pursuant to §103D-307, HRS, and Subchapter 10, Chapter 3-122, HAR, the Department requests approval for the following:

3. Date: **July 17, 2007**

4. After the fact **X** YES ☐ NO

5. Nature of the Emergency

On July 17, 2007, a tire on heavy-lift equipment operated by Hawaii Superferry personnel fell into a sinkhole/void in the Pier 1/Jetty Road yard area at Nawiliwili Harbor, Kauai. The sinkhole was located in an area that would cause operations to shutdown if not repaired. It was discovered that the sinkhole in the pavement, approximately 8' x 10' x 8' deep, was caused by a fireline break. Additionally, approximately 1,000 square feet of surrounding surface pavement was damaged. (See attached pictures)

6. Vendor: Goodfellow Brothers, Inc.
Address: P.O. Box 1090 Koloa, HI 96756

7. Price: ~ $55,000

8. Description of goods, services, or construction to be purchased

The existing 8" ductile iron waterline was repaired and the sinkhole approximately 8' x 10' x 8' deep was backfilled and re-paved. Approximately 1,000 square feet of surrounding pavement was removed, re-compacted, and re-paved to provide safe pedestrian and vehicular access.

9. Reason for Vendor Selection

Two (2) bidders were contacted and immediately available to complete work. Goodfellow Brothers, Inc. was the low bidder.

10. Direct questions to: Branden Sumida Phone: 587-1873

11. ***I certify that the information provided above is to the best of my knowledge, true and correct.***

Department Head or Designee

SEP 12 2007
Date

Reserved for SPO Use Only

12. Chief Procurement Officer's comments:

13.

☒ APPROVED ☐ DISAPPROVED ☐ NO ACTION REQUIRED

Chief Procurement Officer 9/21/07
Date

14. E.P. No. 08-006-J

SPO-02 (Rev. 08//01/2006)