



STATE PROCUREMENT OFFICE
NOTICE & REQUEST FOR SOLE SOURCE

'12 JUN -1 A9:49

STATE PROCUREMENT OFFICE
STATE OF HAWAII

TO: Chief Procurement Officer

FROM: NELHA / DBEDT
Name of Requesting Department

Pursuant to HRS §103D-306 and HAR chapter 3-122, Subchapter 9, the Department requests sole source approval to purchase the following:

1. Describe the goods, services, or construction to be procured.
Gould Model 3409L, 14x18-23 split case centrifugal pump without electric motor, souplng, or steel frame mounting base. This purchase is for a pump, including shaft and impeller.

Table with 2 columns and 2 rows containing vendor name (CBC Inc.), amount of request (\$75,000.00), contract term (June 6.5.12 to 30 Nov 12), and SPO-001 No.

6. Describe in detail the following:
a. The unique features, characteristics, or capabilities of the goods, service or construction.
This purchase is for parts for an existing Gould pump assembly. Only the pump, shaft and impeller will be purchased to replace an existing pump that is currently installed. The current pump is severely corroded and will need to be replaced within the next 6-8 months. The pump must fit onto an existing mounting frame, couple to an existing electric motor and be able to be installed within existing intake and discharge plumbing. A 200 hp. motor, coupling, and mounting base will not be purchased. This is for a pump only that is part of an existing pump assembly (pump, electric motor, large custom mounting frame, etc.).
b. How the unique features, characteristics or capabilities of the goods, service or construction are essential for the department to accomplish its work.
NELHA currently has five of these pump assembly's installed at its largest seawater distribution and pumping station. The pump station currently services eight commercial tenants in HOST Park area of the NELHA facility and serves as a backup seawater distribution for the entire facility. It is imperative that the exact pump be purchased to match the custom made steel fabricated mounting frame, motor/pump coupling, and fit exactly to the existing 200 horsepower electric motor. The pump shaft must match up exactly to the electric motor shaft to prevent vibration at 900 revolutions per minute speed.

7. Describe the efforts and results in determining that this is the only vendor/contractor/service provider who can provide the goods, services or construction.

CBC Inc. in Honolulu is the only authorized vendor for Goulds Pumps in Hawaii. See enclosed/attached memorandum.

8. Alternate source. Describe the other possible sources for the goods, services, or construction that were investigated but did not meet the department's needs.

There are no other possible sources for this pump since we are recommending the purchase of an exact replacement of an existing pump from the manufacturer (Goulds Pump Co. in Ithica, New York). Changing to any other type of pump would require the purchase of the entire pump assembly which would include a large steel mounting base, coupling, and a new electric motor; which would be much more costly. Changing to another manufacturer's pump would also require changing the large (24", 18") plumbing fittings and spacing between these fittings that currently exist. This would also add unnecessary labor and costs that would not be required by just changing the existing pump component.


9. Identify the primary individual(s) who is knowledgeable about this request, who will conduct and manage this process, and has 1) appropriate written delegated procurement authority; 2) completed mandatory training; and 3) who SPO may contact for follow up inquiry, if any.

(Type over "example" and delete cells not used.)


Name of Department Personnel	Division/Agency	Phone Number	E-mail Address
Jan C. War, Operations Manager	NELHA / DBEDT	808-217-0329	janw@nelha.org
Sharyll Kaniho, Fiscal Officer	NELHA / DBEDT	808-327-9585, x234	sheryllk@nelha.org

Department shall ensure adherence to applicable administrative and statutory requirements, including HAR chapter 3-122, Subchapter 15, Cost or Pricing Data if required.

All requirements/approvals and internal controls for this expenditure is the responsibility of the department.
I certify that the information provided is to the best of my knowledge, true and correct.



Department Head Signature



Date

For Chief Procurement Officer Use Only

Date Notice Posted: 6.5.12

Submit written objection to this notice to issue a sole source contract within seven calendar days or as otherwise allowed from date notice posted to:

state.procurement.office@hawaii.gov

Chief Procurement Officer (CPO) Comments:

This approval is for the solicitation process only, HRS section 103D-310(c) and HAR section 3-122-112, shall apply (i.e. vendor is required to be compliant on the Hawaii Compliance Express) and award is required to be posted on the Awards Reporting System.

If there are any questions, please contact Donn Tsuruda-Kashiwabara at 586-0565 or donna.tsuruda-kashiwabara@hawaii.gov.

Approved Disapproved No Action Required

Donn Tsuruda-Kashiwabara 6/27/2012
Chief Procurement Officer Signature Date



ITT Industries
Engineered for life

Goulds Pumps, Inc.
Industrial Process
Western Region
4015 W Topeka Drive
Glendale, AZ 85308

Phone: 602-549-0993
E Mail: Kevin.Gilbreth@itt.com

April 27, 2012


Attention: To whom it may concern

Subject: Hawaii Representation

To Who it May Concern,

I am pleased to advise that CBC, Inc. is the sole distributor in the state of Hawaii for Goulds Pumps industrial and municipal products. Please do not hesitate to call me if you have any questions or concerns.

Sincerely,
ITT Goulds Pumps,


Kevin Gilbreth
Western Regional Sales Manager

SS 12-074D